



MnDOT ADA Compliance Checklist for APS

SP: 9999-99

City: Harveyville

District: M

Intersection: TH 999 and Sample St

Quadrant: NE

Construction Year: 2099

Attach a photo of the completed quadrant by clicking here ->

[Click here to attach a file](#)

[**DO NOT** use Safari on iPads to upload files]: (6MB max)

1) Are push button stations placed and push button faces oriented in accordance with standards? Yes No

2) Is there a minimum 4' x 4' landing adjacent to each push button? Yes No

3) Distance from crosswalk edge to push button face (ft): 6.0 2.0

Trunk Hwy 11.0 7.0

Side Street Trunk Hwy Side Street

4) Distance from the push button to the back of curb: (measured in the direction of the pedestrian travel in ft) 8.0

5) Distance between push buttons (ft): 8.0

Non-compliant due to reasons shown in red boxes

6) Push button height (inches): 42.0 41.0

Trunk Hwy Side Street

7) Push button side reach (inches): 10.0 0.0

Trunk Hwy Side Street

8) Is APS system fully compliant? **NON-COMPLIANT**

If **NO**, check one of the following reasons why. Explain why the component(s) didn't meet compliance (see ADA Compliance Checklist Guidance for additional directions and attach pages if needed).

Topography Structure(s) Utilities Contractor MnDOT

Immovable existing structure restrict proper placement of push button station. Push button not placed correctly by contractor. [Click here to attach a file](#)

9) Has a 6' maintenance access route (MAR) been maintained? Yes No

10) Are push buttons situated at least 2' away from both the back of walk and ramp grade break? Yes No

11) Are all newly constructed hand-hole(s) located outside of pedestrian access route (PAR)? Yes No

12) Push buttons placed according to the plan details? Yes No

If **NO**, please explain:

Printed Name: ADA Date (mm/dd/yyyy): 01/01/2099

I certify that the information entered on this form is accurate to the best of my knowledge and that I fully understand the checklist standards and am qualified to carry out the inspection.

Pg 1

Remember to check box before submitting form.